

SECTION 25

AGGREGATE SUBBASES

25-1.01 Description. - Aggregate subbases shall conform to the requirements of Section 25 of the Caltrans Standard Specifications and these City Standard Specifications.

25-1.02 Materials. - The use of recycled Portland cement concrete or asphalt concrete materials will be permitted, provided that the Contractor submits to the Engineer, laboratory test data that the proposed materials meet all the quality requirements of this section and the Engineer approves its use in writing. Data shall be submitted at least 30 days prior to expected use of the proposed materials in the work. Samples of proposed materials shall be submitted if requested by the Engineer.

25-1.02A Class 1, Class 2, and Class 3 Aggregate Subbases. - Delete the last 4 paragraphs of this subsection.

If no class is specified on the plans or in the special provisions, Class 1 shall be used.

25-1.03 Subgrade. - Delete this subsection. Subgrade preparation shall be as specified in Section 21 of these City Standard Specifications.

25-1.05 Compacting. - Relative compaction shall be determined in accordance with California Tests 216, Part II and 231.

The surface of the finished subbase shall not vary more than 0.08-foot above or below the planned grade at any point and the thickness shall not vary more than 0.08 foot from the thickness shown on the plans at any point. Surfaces will be tested by a 16-foot straight edge applied parallel with and at right angles to the roadway centerline. The Contractor shall furnish the straight edge for the Engineer's use, and it shall be of a type and in a condition approved by the Engineer.

25-1.06 Measurement. - Quantities of aggregate subbase to be paid for by the square yard will be calculated on the basis of the dimensions shown on the plans adjusted by the quantity of any change ordered. No allowance will be made for aggregate subbase placed outside such dimensions unless ordered by the Engineer.

25-1.07 Payment. - Quantities of aggregate subbase will be paid for at the contract price per appropriate unit of measurement, whichever unit is designated in the contract item, for the class or classes involved.